

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on February 13)**

Water Level of the accumulated water (at 16:00 on February 13)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,999 mm (15 mm decrease since 7:00 on February 13)	O.P.+ 3,094 mm (5 mm decrease since 7:00 on February 13)	—
	Water level of Turbine Building	O.P.+ 2,986 mm (6 mm increase since 7:00 on February 13)	O.P.+ 2,975 mm (14 mm decrease since 7:00 on February 13)	O.P.+ 3,006 mm (6 mm decrease since 7:00 on February 13)	O.P.+ 3,013 mm (10 mm decrease since 7:00 on February 13)
	Water level of Reactor Building	O.P.+ 4,285 mm (4 mm decrease since 7:00 on February 13)	O.P.+ 3,179 mm (11 mm decrease since 7:00 on February 13)	O.P.+ 3,320 mm (7 mm decrease since 7:00 on February 13)	O.P.+ 3,035 mm (4 mm decrease since 7:00 on February 13)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,666 mm (Increase from initial level:3,883 mm, 24 mm increase since 16:00 on February 10) O.P.+ 3,339 mm (Increase from initial level:4,065 mm, 80 mm increase since 16:00 on February 10) O.P.+ 4,328 mm (Water level from floor:532 mm, 5 mm increase since 16:00 on February 10)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:43 on February 10)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 9:57 on February 12)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 14:32 on February 10 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.