

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 14)**

Water Level of the accumulated water (at 7:00 on February 14)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,976 mm (23 mm decrease since 16:00 on February 13)	O.P.+ 3,086 mm (8 mm decrease since 16:00 on February 13)	—
	Water level of Turbine Building	O.P.+ 2,996 mm (10 mm increase since 16:00 on February 13)	O.P.+ 2,953 mm (22 mm decrease since 16:00 on February 13)	O.P.+ 2,996 mm (10 mm decrease since 16:00 on February 13)	O.P.+ 3,007 mm (6 mm decrease since 16:00 on February 13)
	Water level of Reactor Building	O.P.+ 4,281 mm (4 mm decrease since 16:00 on February 13)	O.P.+ 3,162 mm (17 mm decrease since 16:00 on February 13)	O.P.+ 3,311 mm (9 mm decrease since 16:00 on February 13)	O.P.+ 3,027 mm (8 mm decrease since 16:00 on February 13)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,701 mm (Increase from initial level:3,918 mm, 35 mm increase since 16:00 on February 13) O.P.+ 3,479 mm (Increase from initial level:4,205 mm, 140 mm increase since 16:00 on February 13) O.P.+ 4,344 mm (Water level from floor:548 mm, 16 mm increase since 16:00 on February 13)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:43 on February 10)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 9:57 on February 12)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): From 14:32 on February 10 to 8:52 on February 14 Operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	At 8:52 am today, we stopped the 2nd Cesium Adsorption Apparatus temporarily and conducted filter cleaning because we confirmed the declining trend of the treatment flow rate at the apparatus.				

For quick publication of the data of water level, values are provided as reference values.