

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 16)**

Water Level of the accumulated water (at 7:00 on February 16)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,022 mm (14 mm increase since 16:00 on February 15)	O.P.+ 3,062 mm (9 mm decrease since 16:00 on February 15)	—
	Water level of Turbine Building	O.P.+ 3,029 mm (11 mm increase since 16:00 on February 15)	O.P.+ 2,996 mm (13 mm increase since 16:00 on February 15)	O.P.+ 2,965 mm (10 mm decrease since 16:00 on February 15)	O.P.+ 2,984 mm (8 mm decrease since 16:00 on February 15)
	Water level of Reactor Building	O.P.+ 4,275 mm (1 mm decrease since 16:00 on February 15)	O.P.+ 3,200 mm (13 mm increase since 16:00 on February 15)	O.P.+ 3,281 mm (10 mm decrease since 16:00 on February 15)	O.P.+ 3,004 mm (8 mm decrease since 16:00 on February 15)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,825 mm (Increase from initial level:4,042 mm, 38 mm increase since 16:00 on February 15) O.P.+ 3,346 mm (Increase from initial level:4,072 mm, 145 mm decrease since 16:00 on February 15) O.P.+ 4,390 mm (Water level from floor:594 mm, 14 mm increase since 16:00 on February 15)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:43 on February 10)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 9:57 on February 12)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 15:40 on February 14 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.