

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 17)**

Water Level of the accumulated water※ (at 7:00 on February 17)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,045 mm (15 mm increase since 16:00 on February 16)	O.P.+ 3,079 mm (17 mm increase since 16:00 on February 16)	—
	Water level of Turbine Building	O.P.+ 3,045 mm (10 mm increase since 16:00 on February 16)	O.P.+ 3,015 mm (12 mm increase since 16:00 on February 16)	O.P.+ 3,001 mm (20 mm increase since 16:00 on February 16)	O.P.+ 2,982 mm (4 mm increase since 16:00 on February 16)
	Water level of Reactor Building	O.P.+ 4,276 mm (2 mm increase since 16:00 on February 16)	O.P.+ 3,225 mm (15 mm increase since 16:00 on February 16)	O.P.+ 3,314 mm (23 mm increase since 16:00 on February 16)	O.P.+ 3,007 mm (7 mm increase since 16:00 on February 16)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,758 mm (Increase from initial level:3,975 mm, 61 mm decrease since 16:00 on February 16) O.P.+ 3,157 mm (Increase from initial level:3,883 mm, 117 mm decrease since 16:00 on February 16) O.P.+ 4,409 mm (Water level from floor:613 mm, 12 mm increase since 16:00 on February 16)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:43 on February 10)	Transfer suspended	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): From 15:40 on February 14 to 8:46 on February 17 Operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* Since the capacity of treatment capacity of the 2nd Cesium adsorption apparatus was declining, we stopped it on 8:46 and cleaned the filters.				

※ For quick publication of the data of water level, values are provided as reference values.