

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on February 17)**

Water Level of the accumulated water (at 16:00 on February 17)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,039 mm (6 mm decrease since 7:00 on February 17)	O.P.+ 3,087 mm (8 mm increase since 7:00 on February 17)	—
	Water level of Turbine Building	O.P.+ 3,050 mm (5 mm increase since 7:00 on February 17)	O.P.+ 3,011 mm (4 mm decrease since 7:00 on February 17)	O.P.+ 3,009 mm (8 mm increase since 7:00 on February 17)	O.P.+ 2,993 mm (11 mm increase since 7:00 on February 17)
	Water level of Reactor Building	O.P.+ 4,278 mm (2 mm increase since 7:00 on February 17)	O.P.+ 3,228 mm (3 mm increase since 7:00 on February 17)	O.P.+ 3,324 mm (10 mm increase since 7:00 on February 17)	O.P.+ 3,014 mm (7 mm increase since 7:00 on February 17)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,719 mm (Increase from initial level:3,936 mm, 39 mm decrease since 7:00 on February 17) O.P.+ 3,249 mm (Increase from initial level:3,975 mm, 92 mm increase since 7:00 on February 17) O.P.+ 4,417 mm (Water level from floor:621 mm, 8 mm increase since 7:00 on February 17)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:43 on February 10)	Transfer suspended	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on February 17 to 16:00 on February 17)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 11:05 on February 17 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* Since the capacity of treatment capacity of the 2nd Cesium adsorption apparatus was declining, we stopped it at 8:46 on Feb 17 and cleaned the filters. We restarted it at 10:59 on the same day, and it reached to the rate flow at 11:05.				

For quick publication of the data of water level, values are provided as reference values.