

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 18)**

Water Level of the accumulated water (at 7:00 on February 18)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,018 mm (21 mm decrease since 16:00 on February 17)	O.P.+ 3,098 mm (11 mm increase since 16:00 on February 17)	—
	Water level of Turbine Building	O.P.+ 3,060 mm (10 mm increase since 16:00 on February 17)	O.P.+ 2,991 mm (20 mm decrease since 16:00 on February 17)	O.P.+ 3,023 mm (14 mm increase since 16:00 on February 17)	O.P.+ 2,997 mm (4 mm increase since 16:00 on February 17)
	Water level of Reactor Building	O.P.+ 4,277 mm (1 mm decrease since 16:00 on February 17)	O.P.+ 3,210 mm (18 mm decrease since 16:00 on February 17)	O.P.+ 3,339 mm (15 mm increase since 16:00 on February 17)	O.P.+ 3,023 mm (9 mm increase since 16:00 on February 17)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,660 mm (Increase from initial level:3,877 mm, 59 mm decrease since 16:00 on February 17) O.P.+ 3,291 mm (Increase from initial level:4,017 mm, 42 mm increase since 16:00 on February 17) O.P.+ 4,430 mm (Water level from floor:634 mm, 13 mm increase since 16:00 on February 17)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:43 on February 10)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 11:05 on February 17 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.