

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on February 18)**

Water Level of the accumulated water (at 16:00 on February 18)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,021 mm (3 mm increase since 7:00 on February 18)	O.P.+ 3,107 mm (9 mm increase since 7:00 on February 18)	—
	Water level of Turbine Building	O.P.+ 3,067 mm (7 mm increase since 7:00 on February 18)	O.P.+ 2,995 mm (4 mm increase since 7:00 on February 18)	O.P.+ 3,032 mm (9 mm increase since 7:00 on February 18)	O.P.+ 3,012 mm (15 mm increase since 7:00 on February 18)
	Water level of Reactor Building	O.P.+ 4,274 mm (3 mm decrease since 7:00 on February 18)	O.P.+ 3,208 mm (2 mm decrease since 7:00 on February 18)	O.P.+ 3,346 mm (7 mm increase since 7:00 on February 18)	O.P.+ 3,029 mm (6 mm increase since 7:00 on February 18)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,624 mm (Increase from initial level:3,841 mm, 36 mm decrease since 7:00 on February 18) O.P.+ 3,227 mm (Increase from initial level:3,953 mm, 64 mm decrease since 7:00 on February 18) O.P.+ 4,437 mm (Water level from floor:641 mm, 7 mm increase since 7:00 on February 18)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:43 on February 10)	—	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank		Transfer Completed	(From 10:00 on February 18 to 16:00 on February 18)
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 11:05 on February 17 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.