

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 19)**

Water Level of the accumulated water (at 7:00 on February 19)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,037 mm (16 mm increase since 16:00 on February 18)	O.P.+ 3,118 mm (11 mm increase since 16:00 on February 18)	—
	Water level of Turbine Building	O.P.+ 3,076 mm (9 mm increase since 16:00 on February 18)	O.P.+ 3,008 mm (13 mm increase since 16:00 on February 18)	O.P.+ 3,044 mm (12 mm increase since 16:00 on February 18)	O.P.+ 3,020 mm (8 mm increase since 16:00 on February 18)
	Water level of Reactor Building	O.P.+ 4,267 mm (7 mm decrease since 16:00 on February 18)	O.P.+ 3,220 mm (12 mm increase since 16:00 on February 18)	O.P.+ 3,361 mm (15 mm increase since 16:00 on February 18)	O.P.+ 3,040 mm (11 mm increase since 16:00 on February 18)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,565 mm (Increase from initial level:3,782 mm, 59 mm decrease since 16:00 on February 18) O.P.+ 3,064 mm (Increase from initial level:3,790 mm, 163 mm decrease since 16:00 on February 18) O.P.+ 4,451 mm (Water level from floor:655 mm, 14 mm increase since 16:00 on February 18)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:43 on February 10)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 11:05 on February 17 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.