

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on February 19)**

Water Level of the accumulated water (at 16:00 on February 19)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,044 mm (7 mm increase since 7:00 on February 19)	O.P.+ 3,126 mm (8 mm increase since 7:00 on February 19)	—
	Water level of Turbine Building	O.P.+ 3,082 mm (6 mm increase since 7:00 on February 19)	O.P.+ 3,014 mm (6 mm increase since 7:00 on February 19)	O.P.+ 3,051 mm (7 mm increase since 7:00 on February 19)	O.P.+ 3,028 mm (8 mm increase since 7:00 on February 19)
	Water level of Reactor Building	O.P.+ 4,262 mm (5 mm decrease since 7:00 on February 19)	O.P.+ 3,227 mm (7 mm increase since 7:00 on February 19)	O.P.+ 3,368 mm (7 mm increase since 7:00 on February 19)	O.P.+ 3,047 mm (7 mm increase since 7:00 on February 19)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,532 mm (Increase from initial level:3,749 mm, 33 mm decrease since 7:00 on February 19) O.P.+ 2,977 mm (Increase from initial level:3,703 mm, 87 mm decrease since 7:00 on February 19) O.P.+ 4,460 mm (Water level from floor:664 mm, 9 mm increase since 7:00 on February 19)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:43 on February 10)	—	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on February 19 to 16:00 on February 19)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 11:05 on February 17 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.