

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 20)**

Water Level of the accumulated water (at 7:00 on February 20)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,057 mm (13 mm increase since 16:00 on February 19)	O.P.+ 3,136 mm (10 mm increase since 16:00 on February 19)	—
	Water level of Turbine Building	O.P.+ 3,090 mm (8 mm increase since 16:00 on February 19)	O.P.+ 3,024 mm (10 mm increase since 16:00 on February 19)	O.P.+ 3,063 mm (12 mm increase since 16:00 on February 19)	O.P.+ 3,044 mm (16 mm increase since 16:00 on February 19)
	Water level of Reactor Building	O.P.+ 4,266 mm (4 mm increase since 16:00 on February 19)	O.P.+ 3,237 mm (10 mm increase since 16:00 on February 19)	O.P.+ 3,381 mm (13 mm increase since 16:00 on February 19)	O.P.+ 3,058 mm (11 mm increase since 16:00 on February 19)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,473 mm (Increase from initial level:3,690 mm, 59 mm decrease since 16:00 on February 19) O.P.+ 2,845 mm (Increase from initial level:3,571 mm, 132 mm decrease since 16:00 on February 19) O.P.+ 4,466 mm (Water level from floor:670 mm, 6 mm increase since 16:00 on February 19)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:43 on February 10)		—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): From 11:05 on February 17 to 8:35 on February 20 Operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	As the treatment flow rate of the 2nd Cesium adsorption apparatus showed a downward tendency, at 8:35 today, we suspended it and washed its filters.				

For quick publication of the data of water level, values are provided as reference values.