

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 21)**

Water Level of the accumulated water (at 7:00 on February 21)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,098 mm (12 mm increase since 16:00 on February 20)	O.P.+ 3,124 mm (8 mm decrease since 16:00 on February 20)	—
	Water level of Turbine Building	O.P.+ 3,105 mm (9 mm increase since 16:00 on February 20)	O.P.+ 3,062 mm (13 mm increase since 16:00 on February 20)	O.P.+ 3,036 mm (16 mm decrease since 16:00 on February 20)	O.P.+ 3,041 mm (6 mm decrease since 16:00 on February 20)
	Water level of Reactor Building	O.P.+ 4,240 mm (1 mm decrease since 16:00 on February 20)	O.P.+ 3,266 mm (16 mm increase since 16:00 on February 20)	O.P.+ 3,357 mm (18 mm decrease since 16:00 on February 20)	O.P.+ 3,061 mm (3 mm decrease since 16:00 on February 20)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,381 mm (Increase from initial level:3,598 mm, 58 mm decrease since 16:00 on February 20) O.P.+ 3,135 mm (Increase from initial level:3,861 mm, 140 mm increase since 16:00 on February 20) O.P.+ 4,505 mm (Water level from floor:709 mm, 18 mm increase since 16:00 on February 20)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:39 on February 20)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:30 on February 20)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 11:11 on February 20 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.