

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 22)**

Water Level of the accumulated water (at 7:00 on February 22)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,127 mm (4 mm increase since 16:00 on February 21)	O.P.+ 3,111 mm (9 mm decrease since 16:00 on February 21)	—
	Water level of Turbine Building	O.P.+ 3,120 mm (9 mm increase since 16:00 on February 21)	O.P.+ 3,089 mm (8 mm increase since 16:00 on February 21)	O.P.+ 3,019 mm (10 mm decrease since 16:00 on February 21)	O.P.+ 3,030 mm (9 mm decrease since 16:00 on February 21)
	Water level of Reactor Building	O.P.+ 4,266 mm (15 mm increase since 16:00 on February 21)	O.P.+ 3,286 mm (8 mm increase since 16:00 on February 21)	O.P.+ 3,339 mm (11 mm decrease since 16:00 on February 21)	O.P.+ 3,051 mm (8 mm decrease since 16:00 on February 21)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,353 mm (Increase from initial level:3,570 mm, 51 mm decrease since 16:00 on February 21) O.P.+ 3,417 mm (Increase from initial level:4,143 mm, 178 mm increase since 16:00 on February 21) O.P.+ 4,301 mm (Water level from floor:505 mm, 14 mm increase since 16:00 on February 21)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:39 on February 20)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:30 on February 20)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 11:11 on February 20 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.