

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 23)**

Water Level of the accumulated water (at 7:00 on February 23)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,145 mm (5 mm increase since 16:00 on February 22)	O.P.+ 3,127 mm (15 mm increase since 16:00 on February 22)	—
	Water level of Turbine Building	O.P.+ 3,135 mm (9 mm increase since 16:00 on February 22)	O.P.+ 3,104 mm (7 mm increase since 16:00 on February 22)	O.P.+ 3,050 mm (17 mm increase since 16:00 on February 22)	O.P.+ 3,029 mm (1 mm increase since 16:00 on February 22)
	Water level of Reactor Building	O.P.+ 4,248 mm (1 mm decrease since 16:00 on February 22)	O.P.+ 3,297 mm (6 mm increase since 16:00 on February 22)	O.P.+ 3,368 mm (21 mm increase since 16:00 on February 22)	O.P.+ 3,054 mm (5 mm increase since 16:00 on February 22)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,263 mm (Increase from initial level:3,480 mm, 57 mm decrease since 16:00 on February 22) O.P.+ 3,280 mm (Increase from initial level:4,006 mm, 121 mm decrease since 16:00 on February 22) O.P.+ 4,324 mm (Water level from floor:528 mm, 15 mm increase since 16:00 on February 22)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 9:39 on February 20 to 8:28 on February 23)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 11:11 on February 20 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.