

Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 18:00 on February 23)

Water Level of the accumulated water (at 16:00 on February 23)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,165 mm (20 mm increase since 7:00 on February 23)	O.P.+ 3,136 mm (9 mm increase since 7:00 on February 23)	—
	Water level of Turbine Building	O.P.+ 3,144 mm (9 mm increase since 7:00 on February 23)	O.P.+ 3,120 mm (16 mm increase since 7:00 on February 23)	O.P.+ 3,061 mm (11 mm increase since 7:00 on February 23)	O.P.+ 3,042 mm (13 mm increase since 7:00 on February 23)
	Water level of Reactor Building	O.P.+ 4,281 mm (33 mm increase since 7:00 on February 23)	O.P.+ 3,318 mm (21 mm increase since 7:00 on February 23)	O.P.+ 3,381 mm (13 mm increase since 7:00 on February 23)	O.P.+ 3,064 mm (10 mm increase since 7:00 on February 23)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,250 mm (Increase from initial level:3,467 mm, 13 mm decrease since 7:00 on February 23) O.P.+ 3,043 mm (Increase from initial level:3,769 mm, 237 mm decrease since 7:00 on February 23) O.P.+ 4,333 mm (Water level from floor:537 mm, 9 mm increase since 7:00 on February 23)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 14:04 on February 23)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 11:11 on February 20 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.