

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 24)**

Water Level of the accumulated water (at 7:00 on February 24)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,114 mm (51 mm decrease since 16:00 on February 23)	O.P.+ 3,150 mm (14 mm increase since 16:00 on February 23)	—
	Water level of Turbine Building	O.P.+ 3,155 mm (11 mm increase since 16:00 on February 23)	O.P.+ 3,076 mm (44 mm decrease since 16:00 on February 23)	O.P.+ 3,074 mm (13 mm increase since 16:00 on February 23)	O.P.+ 3,055 mm (13 mm increase since 16:00 on February 23)
	Water level of Reactor Building	O.P.+ 4,331 mm (50 mm increase since 16:00 on February 23)	O.P.+ 3,278 mm (40 mm decrease since 16:00 on February 23)	O.P.+ 3,393 mm (12 mm increase since 16:00 on February 23)	O.P.+ 3,073 mm (9 mm increase since 16:00 on February 23)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,387 mm (Increase from initial level:3,604 mm, 137 mm increase since 16:00 on February 23) O.P.+ 2,659 mm (Increase from initial level:3,385 mm, 384 mm decrease since 16:00 on February 23) O.P.+ 4,347 mm (Water level from floor:551 mm, 14 mm increase since 16:00 on February 23)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 14:04 on February 23)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): From 11:11 on February 20 to 8:21 on February 24 Operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	Operation of second Cesium Adsorption Apparatus was temporarily suspended at 8:21 am today and we washed filters as an amount of the treated water was observed to decrease.				

For quick publication of the data of water level, values are provided as reference values.