

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on February 24)**

Water Level of the accumulated water (at 16:00 on February 24)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,085 mm (29 mm decrease since 7:00 on February 24)	O.P.+ 3,157 mm (7 mm increase since 7:00 on February 24)	—
	Water level of Turbine Building	O.P.+ 3,162 mm (7 mm increase since 7:00 on February 24)	O.P.+ 3,050 mm (26 mm decrease since 7:00 on February 24)	O.P.+ 3,082 mm (8 mm increase since 7:00 on February 24)	O.P.+ 3,064 mm (9 mm increase since 7:00 on February 24)
	Water level of Reactor Building	O.P.+ 4,324 mm (7 mm decrease since 7:00 on February 24)	O.P.+ 3,250 mm (28 mm decrease since 7:00 on February 24)	O.P.+ 3,402 mm (9 mm increase since 7:00 on February 24)	O.P.+ 3,080 mm (7 mm increase since 7:00 on February 24)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,475 mm (Increase from initial level:3,692 mm, 88 mm increase since 7:00 on February 24) O.P.+ 2,512 mm (Increase from initial level:3,238 mm, 147 mm decrease since 7:00 on February 24) O.P.+ 4,356 mm (Water level from floor:560 mm, 9 mm increase since 7:00 on February 24)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 14:04 on February 23)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 10:32 on February 24 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	At 8:21 am on February 24, as the gradual decline in the treated water amount was observed in the second Cesium Adsorption Apparatus, its operation was temporarily suspended to implement the washing of the filter. At 10:30 am on the same day, the operation was restated and designed water flow was achieved at 10:32 am.				

For quick publication of the data of water level, values are provided as reference values.