

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 27)**

Water Level of the accumulated water (at 7:00 on February 27)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,959 mm (36 mm decrease since 16:00 on February 26)	O.P.+ 3,149 mm (8 mm decrease since 16:00 on February 26)	—
	Water level of Turbine Building	O.P.+ 2,828 mm (12 mm increase since 16:00 on February 26)	O.P.+ 2,937 mm (30 mm decrease since 16:00 on February 26)	O.P.+ 3,055 mm (12 mm decrease since 16:00 on February 26)	O.P.+ 3,065 mm (9 mm decrease since 16:00 on February 26)
	Water level of Reactor Building	O.P.+ 4,312 mm (6 mm decrease since 16:00 on February 26)	O.P.+ 3,137 mm (31 mm decrease since 16:00 on February 26)	O.P.+ 3,379 mm (13 mm decrease since 16:00 on February 26)	O.P.+ 3,086 mm (7 mm decrease since 16:00 on February 26)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,849 mm (Increase from initial level:4,066 mm, 57 mm decrease since 16:00 on February 26) O.P.+ 2,637 mm (Increase from initial level:3,363 mm, 304 mm increase since 16:00 on February 26) O.P.+ 4,412 mm (Water level from floor:616 mm, 15 mm increase since 16:00 on February 26)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:04 on February 26)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:09 on February 25)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 13:50 on February 26 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.