

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 28)**

Water Level of the accumulated water (at 7:00 on February 28)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,975 mm (1 mm increase since 16:00 on February 27)	O.P.+ 3,119 mm (13 mm decrease since 16:00 on February 27)	—
	Water level of Turbine Building	O.P.+ 2,845 mm (11 mm increase since 16:00 on February 27)	O.P.+ 2,952 mm (3 mm increase since 16:00 on February 27)	O.P.+ 3,034 mm (13 mm decrease since 16:00 on February 27)	O.P.+ 3,043 mm (17 mm decrease since 16:00 on February 27)
	Water level of Reactor Building	O.P.+ 4,296 mm (11 mm decrease since 16:00 on February 27)	O.P.+ 3,144 mm (10 mm increase since 16:00 on February 27)	O.P.+ 3,358 mm (13 mm decrease since 16:00 on February 27)	O.P.+ 3,066 mm (15 mm decrease since 16:00 on February 27)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,898 mm (Increase from initial level:4,115 mm, 58 mm increase since 16:00 on February 27) O.P.+ 2,543 mm (Increase from initial level:3,269 mm, 124 mm decrease since 16:00 on February 27) O.P.+ 4,435 mm (Water level from floor:639 mm, 14 mm increase since 16:00 on February 27)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:50 on February 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:09 on February 25)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 13:50 on February 26 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	According to the investigation on trenches on January 19, 2012, high density contaminated water was found inside circulating water pump discharge valve pit in water pump room of Unit and 3. Therefore, at 8:51today, we started transfer of the accumulated water from the pit to the basement of Unit 2 Turbine Building.				

For quick publication of the data of water level, values are provided as reference values.