Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 18:00 on February 28)

| | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
|--|--|--|---|---|--|
| Water Level of the accumulated water (at 16:00 on February 28) | Water level of Vertical Shaft | Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm) | O.P.+ 2,999 mm (24 mm increase since 7:00 on February 28) | O.P.+ 3,090 mm (29 mm decrease since 7:00 on February 28) | |
| | Water level of Turbine Building | O.P.+ 2,852 mm (7 mm increase since 7:00 on February 28) | O.P.+ 2,973 mm (21 mm increase since 7:00 on February 28) | O.P.+ 3,025 mm (9 mm decrease since 7:00 on February 28) | O.P.+ 3,040 mm (3 mm decrease since 7:00 on February 28) |
| | Water level of Reactor Building | O.P.+ 4,281 mm (15 mm decrease since 7:00 on February 28) | O.P.+ 3,157 mm (13 mm increase since 7:00 on February 28) | O.P.+ 3,351 mm (7 mm decrease since 7:00 on February 28) | O.P.+ 3,057 mm (9 mm decrease since 7:00 on February 28) |
| | Water level of each building in the Centralized Radiation Waste | Process Main Building | O.P.+ 2,923 mm (Increase from initial level:4,140 mm, 25 mm increase since 7:00 on February 28) | | |
| | | High Temperature Incinerator Building | O.P.+ 2,481 mm (Increase from initial level:3,207 mm, 62 mm decrease since 7:00 on February 28) | | |
| | Treatment Facility | On-site Bunker Building | O.P.+ 4,443 mm (Water level from floor:647 mm, 8 mm increase since 7:00 on February 28) | | |
| Situation of transfer of the accumulated water | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | | _ | Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 14:00 on February 28) | Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 13:56 on February 28) | _ |
| | | Unit 5 and 6 | | | |
| | | | _ | | |
| Operation condition of water treatment facility | | Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 13:50 on February 26 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance | | | |
| Notes | Since in the trench inspection of January 19, highly contaminated water was confirmed to be accumulated in the discharge valve of the cyclic water pump in the Unit 3 pump room, from 8:51 am to 3:45 pm we transferred the accumulated water from the pit to the basement of the Unit 2 turbine building. | | | | |

For quick publication of the data of water level, values are provided as reference values.