

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 29)**

Water Level of the accumulated water (at 7:00 on February 29)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,997 mm (2 mm decrease since 16:00 on February 28)	O.P.+ 3,080 mm (10 mm decrease since 16:00 on February 28)	—
	Water level of Turbine Building	O.P.+ 2,862 mm (10 mm increase since 16:00 on February 28)	O.P.+ 2,966 mm (7 mm decrease since 16:00 on February 28)	O.P.+ 3,011 mm (14 mm decrease since 16:00 on February 28)	O.P.+ 3,024 mm (16 mm decrease since 16:00 on February 28)
	Water level of Reactor Building	O.P.+ 4,264 mm (17 mm decrease since 16:00 on February 28)	O.P.+ 3,161 mm (4 mm increase since 16:00 on February 28)	O.P.+ 3,337 mm (14 mm decrease since 16:00 on February 28)	O.P.+ 3,048 mm (9 mm decrease since 16:00 on February 28)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,970 mm (Increase from initial level:4,187 mm, 47 mm increase since 16:00 on February 28) O.P.+ 2,387 mm (Increase from initial level:3,113 mm, 94 mm decrease since 16:00 on February 28) O.P.+ 4,455 mm (Water level from floor:659 mm, 12 mm increase since 16:00 on February 28)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 14:00 on February 28)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 13:56 on February 28)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 13:50 on February 26 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	As we found high concentrated contaminated water accumulated within the pit of Unit 3 pump room circulating water discharge valve when investigating the trenches on January 19, since 8:17 am today we have started transfer of the accumulated water from the pit towards the Unit 2 Turbine Building basement.				

For quick publication of the data of water level, values are provided as reference values.