

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 1)**

Water Level of the accumulated water (at 7:00 on March 1)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,013 mm (4 mm decrease since 16:00 on February 29)	O.P.+ 3,039 mm (7 mm decrease since 16:00 on February 29)	—
	Water level of Turbine Building	O.P.+ 2,880 mm (11 mm increase since 16:00 on February 29)	O.P.+ 2,979 mm (4 mm decrease since 16:00 on February 29)	O.P.+ 2,991 mm (12 mm decrease since 16:00 on February 29)	O.P.+ 3,004 mm (11 mm decrease since 16:00 on February 29)
	Water level of Reactor Building	O.P.+ 4,266 mm (15 mm increase since 16:00 on February 29)	O.P.+ 3,174 mm (3 mm increase since 16:00 on February 29)	O.P.+ 3,316 mm (13 mm decrease since 16:00 on February 29)	O.P.+ 3,029 mm (11 mm decrease since 16:00 on February 29)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,052 mm (Increase from initial level:4,269 mm, 51 mm increase since 16:00 on February 29) O.P.+ 2,243 mm (Increase from initial level:2,969 mm, 128 mm decrease since 16:00 on February 29) O.P.+ 4,483 mm (Water level from floor:687 mm, 19 mm increase since 16:00 on February 29)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 14:00 on February 28)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 13:56 on February 28)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:45 on March 1 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 10:12 on February 29 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	·At 8:26 am today, we started transferring the water accumulated in the outlet pit of the circular water pump in the Unit 3 pump room to the basement of Unit 2 Turbine Building, since it was found by the surveys on trenched on Jan 19 that the high level radioactive waste water was accumulated in the pit. ·In order to conduct the work to improve the reliability of water treatment facilities, we stopped the cesium adsorption apparatus at 8:45 am today. It will be out of service until March 15.				

For quick publication of the data of water level, values are provided as reference values.