

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on March 1)**

Water Level of the accumulated water (at 16:00 on March 1)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,034 mm (21 mm increase since 7:00 on March 1)	O.P.+ 3,013 mm (26 mm decrease since 7:00 on March 1)	—
	Water level of Turbine Building	O.P.+ 2,889 mm (9 mm increase since 7:00 on March 1)	O.P.+ 2,997 mm (18 mm increase since 7:00 on March 1)	O.P.+ 2,984 mm (7 mm decrease since 7:00 on March 1)	O.P.+ 2,993 mm (11 mm decrease since 7:00 on March 1)
	Water level of Reactor Building	O.P.+ 4,262 mm (4 mm decrease since 7:00 on March 1)	O.P.+ 3,185 mm (11 mm increase since 7:00 on March 1)	O.P.+ 3,307 mm (9 mm decrease since 7:00 on March 1)	O.P.+ 3,021 mm (8 mm decrease since 7:00 on March 1)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,127 mm (Increase from initial level:4,344 mm, 75 mm increase since 7:00 on March 1) O.P.+ 2,171 mm (Increase from initial level:2,897 mm, 72 mm decrease since 7:00 on March 1) O.P.+ 4,495 mm (Water level from floor:699 mm, 12 mm increase since 7:00 on March 1)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 14:00 on February 28)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 13:56 on February 28)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on March 1 to 16:00 on March 1)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:45 on March 1 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 10:12 on February 29 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	• From 8:26 am to 3:18 pm today, we transferred the water accumulated in the outlet pit of the circular water pump in the Unit 3 pump room to the basement of Unit 2 Turbine Building, since it was found by the surveys on trenches on Jan 19 that the high level radioactive waste water was accumulated in the pit. • In order to conduct the work to improve the reliability of water treatment facilities, we stopped the cesium adsorption apparatus at 8:45 am today. It will be out of service until March 15.				

For quick publication of the data of water level, values are provided as reference values.