

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 2)**

Water Level of the accumulated water (at 7:00 on March 2)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,029 mm (5 mm decrease since 16:00 on March 1)	O.P.+ 3,008 mm (5 mm decrease since 16:00 on March 1)	—
	Water level of Turbine Building	O.P.+ 2,900 mm (11 mm increase since 16:00 on March 1)	O.P.+ 2,992 mm (5 mm decrease since 16:00 on March 1)	O.P.+ 2,971 mm (13 mm decrease since 16:00 on March 1)	O.P.+ 2,980 mm (13 mm decrease since 16:00 on March 1)
	Water level of Reactor Building	O.P.+ 4,267 mm (5 mm increase since 16:00 on March 1)	O.P.+ 3,187 mm (2 mm increase since 16:00 on March 1)	O.P.+ 3,295 mm (12 mm decrease since 16:00 on March 1)	O.P.+ 3,010 mm (11 mm decrease since 16:00 on March 1)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,265 mm (Increase from initial level:4,482 mm, 138 mm increase since 16:00 on March 1) O.P.+ 2,058 mm (Increase from initial level:2,784 mm, 113 mm decrease since 16:00 on March 1) O.P.+ 4,516 mm (Water level from floor:720 mm, 21 mm increase since 16:00 on March 1)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 14:00 on February 28)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 13:56 on February 28)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:45 on March 1   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:07 on March 2   Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	In order to conduct the work to improve the reliability of water treatment facilities, the cesium adsorption apparatus will be out of service until March 15. In order to conduct the work to improve the reliability of water treatment facilities, we stopped the 2nd Cesium Adsorption Apparatus at 8:07 am today. It will be out of service until March 10.				

For quick publication of the data of water level, values are provided as reference values.