

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 3)**

Water Level of the accumulated water※ (at 7:00 on March 3)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,024 mm (3 mm decrease since 16:00 on March 2)	O.P.+ 2,998 mm (7 mm decrease since 16:00 on March 2)	—
	Water level of Turbine Building	O.P.+ 2,921 mm (14 mm increase since 16:00 on March 2)	O.P.+ 2,986 mm (4 mm decrease since 16:00 on March 2)	O.P.+ 2,957 mm (8 mm decrease since 16:00 on March 2)	O.P.+ 2,972 mm (13 mm decrease since 16:00 on March 2)
	Water level of Reactor Building	O.P.+ 4,304 mm (39 mm increase since 16:00 on March 2)	O.P.+ 3,182 mm (4 mm decrease since 16:00 on March 2)	O.P.+ 3,283 mm (6 mm decrease since 16:00 on March 2)	O.P.+ 3,001 mm (6 mm decrease since 16:00 on March 2)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,561 mm (Increase from initial level:4,778 mm, 186 mm increase since 16:00 on March 2) O.P.+ 2,473 mm (Increase from initial level:3,199 mm, 252 mm increase since 16:00 on March 2) O.P.+ 4,548 mm (Water level from floor:752 mm, 19 mm increase since 16:00 on March 2)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 14:00 on February 28)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 13:56 on February 28)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:45 on March 1 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:07 on March 2 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	In order to conduct the work to improve the reliability of water treatment facilities, the cesium adsorption apparatus will be out of service until March 15. In order to conduct the work to improve the reliability of water treatment facilities, the 2nd Cesium Adsorption Apparatus will be out of service until March 10.				

※ For quick publication of the data of water level, values are provided as reference values.