

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on March 4)**

Water Level of the accumulated water (at 16:00 on March 4)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,023 mm (No change since 7:00 on March 4)	O.P.+ 2,994 mm (1 mm increase since 7:00 on March 4)	—
	Water level of Turbine Building	O.P.+ 2,955 mm (8 mm increase since 7:00 on March 4)	O.P.+ 2,985 mm (1 mm decrease since 7:00 on March 4)	O.P.+ 2,966 mm (9 mm increase since 7:00 on March 4)	O.P.+ 2,965 mm (5 mm decrease since 7:00 on March 4)
	Water level of Reactor Building	O.P.+ 4,333 mm (16 mm decrease since 7:00 on March 4)	O.P.+ 3,184 mm (3 mm increase since 7:00 on March 4)	O.P.+ 3,287 mm (11 mm increase since 7:00 on March 4)	O.P.+ 2,992 mm (3 mm decrease since 7:00 on March 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,068 mm (Increase from initial level:5,285 mm, 113 mm increase since 7:00 on March 4) O.P.+ 2,922 mm (Increase from initial level:3,648 mm, 48 mm increase since 7:00 on March 4) O.P.+ 4,340 mm (Water level from floor:544 mm, 10 mm increase since 7:00 on March 4)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 14:00 on February 28)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 13:56 on February 28 to 9:54 on March 4)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:45 on March 1 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:07 on March 2 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	·In order to conduct the work to improve the reliability of water treatment facilities, the cesium adsorption apparatus will be out of service until March 15. ·In order to conduct the work to improve the reliability of water treatment facilities, the 2nd Cesium Adsorption Apparatus will be out of service until March 10.				

For quick publication of the data of water level, values are provided as reference values.