

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 5)**

Water Level of the accumulated water (at 7:00 on March 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,023 mm (No change since 16:00 on March 4)	O.P.+ 3,010 mm (16 mm increase since 16:00 on March 4)	—
	Water level of Turbine Building	O.P.+ 2,969 mm (14 mm increase since 16:00 on March 4)	O.P.+ 2,985 mm (No change since 16:00 on March 4)	O.P.+ 2,987 mm (21 mm increase since 16:00 on March 4)	O.P.+ 2,976 mm (11 mm increase since 16:00 on March 4)
	Water level of Reactor Building	O.P.+ 4,343 mm (10 mm increase since 16:00 on March 4)	O.P.+ 3,184 mm (No change since 16:00 on March 4)	O.P.+ 3,312 mm (25 mm increase since 16:00 on March 4)	O.P.+ 2,999 mm (7 mm increase since 16:00 on March 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,256 mm (Increase from initial level:5,473 mm, 188 mm increase since 16:00 on March 4) O.P.+ 2,897 mm (Increase from initial level:3,623 mm, 25 mm decrease since 16:00 on March 4) O.P.+ 4,354 mm (Water level from floor:558 mm, 14 mm increase since 16:00 on March 4)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 14:00 on February 28)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:45 on March 1   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:07 on March 2   Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	・In order to conduct the work to improve the reliability of water treatment facilities, the cesium adsorption apparatus will be out of service until March 15. ・In order to conduct the work to improve the reliability of water treatment facilities, the 2nd Cesium Adsorption Apparatus will be out of service until March 10.				

For quick publication of the data of water level, values are provided as reference values.