

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on March 5)**

Water Level of the accumulated water (at 16:00 on March 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,058 mm (35 mm increase since 7:00 on March 5)	O.P.+ 3,028 mm (18 mm increase since 7:00 on March 5)	—
	Water level of Turbine Building	O.P.+ 2,986 mm (17 mm increase since 7:00 on March 5)	O.P.+ 3,015 mm (30 mm increase since 7:00 on March 5)	O.P.+ 3,007 mm (20 mm increase since 7:00 on March 5)	O.P.+ 2,985 mm (9 mm increase since 7:00 on March 5)
	Water level of Reactor Building	O.P.+ 4,410 mm (67 mm increase since 7:00 on March 5)	O.P.+ 3,213 mm (29 mm increase since 7:00 on March 5)	O.P.+ 3,336 mm (24 mm increase since 7:00 on March 5)	O.P.+ 3,013 mm (14 mm increase since 7:00 on March 5)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,306 mm (Increase from initial level:5,523 mm, 50 mm increase since 7:00 on March 5) O.P.+ 2,898 mm (Increase from initial level:3,624 mm, 1 mm increase since 7:00 on March 5) O.P.+ 4,365 mm (Water level from floor:569 mm, 11 mm increase since 7:00 on March 5)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Transfer Completed (From 14:00 on February 28 to 10:09 on March 5)	—	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on March 5 to 16:00 on March 5)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:45 on March 1 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:07 on March 2 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	· In order to conduct the work to improve the reliability of water treatment facilities, the cesium adsorption apparatus will be out of service until March 15. · In order to conduct the work to improve the reliability of water treatment facilities, the 2nd Cesium Adsorption Apparatus will be out of service until March 10.				

For quick publication of the data of water level, values are provided as reference values.