

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 6)**

Water Level of the accumulated water (at 7:00 on March 6)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,129 mm (71 mm increase since 16:00 on March 5)	O.P.+ 3,053 mm (25 mm increase since 16:00 on March 5)	—
	Water level of Turbine Building	O.P.+ 3,015 mm (29 mm increase since 16:00 on March 5)	O.P.+ 3,080 mm (65 mm increase since 16:00 on March 5)	O.P.+ 3,033 mm (26 mm increase since 16:00 on March 5)	O.P.+ 3,008 mm (23 mm increase since 16:00 on March 5)
	Water level of Reactor Building	O.P.+ 4,530 mm (120 mm increase since 16:00 on March 5)	O.P.+ 3,265 mm (52 mm increase since 16:00 on March 5)	O.P.+ 3,360 mm (24 mm increase since 16:00 on March 5)	O.P.+ 3,033 mm (20 mm increase since 16:00 on March 5)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,315 mm (Increase from initial level:5,532 mm, 9 mm increase since 16:00 on March 5) O.P.+ 2,904 mm (Increase from initial level:3,630 mm, 6 mm increase since 16:00 on March 5) O.P.+ 4,381 mm (Water level from floor:585 mm, 16 mm increase since 16:00 on March 5)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:45 on March 1   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:07 on March 2   Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	・In order to conduct the work to improve the reliability of water treatment facilities, the cesium adsorption apparatus will be out of service until March 15. ・In order to conduct the work to improve the reliability of water treatment facilities, the 2nd Cesium Adsorption Apparatus will be out of service until March 10.				

For quick publication of the data of water level, values are provided as reference values.