

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on March 6)**

Water Level of the accumulated water (at 16:00 on March 6)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,170 mm (41 mm increase since 7:00 on March 6)	O.P.+ 3,064 mm (11 mm increase since 7:00 on March 6)	—
	Water level of Turbine Building	O.P.+ 3,027 mm (12 mm increase since 7:00 on March 6)	O.P.+ 3,117 mm (37 mm increase since 7:00 on March 6)	O.P.+ 3,044 mm (11 mm increase since 7:00 on March 6)	O.P.+ 3,023 mm (15 mm increase since 7:00 on March 6)
	Water level of Reactor Building	O.P.+ 4,590 mm (60 mm increase since 7:00 on March 6)	O.P.+ 3,301 mm (36 mm increase since 7:00 on March 6)	O.P.+ 3,370 mm (10 mm increase since 7:00 on March 6)	O.P.+ 3,043 mm (10 mm increase since 7:00 on March 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,322 mm (Increase from initial level:5,539 mm, 7 mm increase since 7:00 on March 6) O.P.+ 2,915 mm (Increase from initial level:3,641 mm, 11 mm increase since 7:00 on March 6) O.P.+ 4,391 mm (Water level from floor:595 mm, 10 mm increase since 7:00 on March 6)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:45 on March 1 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:07 on March 2 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	·In order to conduct the work to improve the reliability of water treatment facilities, the cesium adsorption apparatus will be out of service until March 15. ·In order to conduct the work to improve the reliability of water treatment facilities, the 2nd Cesium Adsorption Apparatus will be out of service until March 10.				

For quick publication of the data of water level, values are provided as reference values.