

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 7)**

Water Level of the accumulated water (at 7:00 on March 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,234 mm (64 mm increase since 16:00 on March 6)	O.P.+ 3,079 mm (15 mm increase since 16:00 on March 6)	—
	Water level of Turbine Building	O.P.+ 3,047 mm (20 mm increase since 16:00 on March 6)	O.P.+ 3,174 mm (57 mm increase since 16:00 on March 6)	O.P.+ 3,061 mm (17 mm increase since 16:00 on March 6)	O.P.+ 3,036 mm (13 mm increase since 16:00 on March 6)
	Water level of Reactor Building	O.P.+ 4,635 mm (45 mm increase since 16:00 on March 6)	O.P.+ 3,355 mm (54 mm increase since 16:00 on March 6)	O.P.+ 3,385 mm (15 mm increase since 16:00 on March 6)	O.P.+ 3,057 mm (14 mm increase since 16:00 on March 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,335 mm (Increase from initial level:5,552 mm, 13 mm increase since 16:00 on March 6) O.P.+ 2,917 mm (Increase from initial level:3,643 mm, 2 mm increase since 16:00 on March 6) O.P.+ 4,408 mm (Water level from floor:612 mm, 17 mm increase since 16:00 on March 6)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:45 on March 1   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:07 on March 2   Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	・In order to conduct the work to improve the reliability of water treatment facilities, the cesium adsorption apparatus will be out of service until March 15. ・In order to conduct the work to improve the reliability of water treatment facilities, the 2nd Cesium Adsorption Apparatus will be out of service until March 10.				

For quick publication of the data of water level, values are provided as reference values.