

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 8)**

Water Level of the accumulated water (at 7:00 on March 8)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,256 mm (6 mm decrease since 16:00 on March 7)	O.P.+ 3,077 mm (8 mm decrease since 16:00 on March 7)	—
	Water level of Turbine Building	O.P.+ 3,076 mm (18 mm increase since 16:00 on March 7)	O.P.+ 3,192 mm (5 mm decrease since 16:00 on March 7)	O.P.+ 3,040 mm (22 mm decrease since 16:00 on March 7)	O.P.+ 3,045 mm (1 mm decrease since 16:00 on March 7)
	Water level of Reactor Building	O.P.+ 4,631 mm (15 mm decrease since 16:00 on March 7)	O.P.+ 3,382 mm (2 mm decrease since 16:00 on March 7)	O.P.+ 3,371 mm (20 mm decrease since 16:00 on March 7)	O.P.+ 3,066 mm (2 mm increase since 16:00 on March 7)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,656 mm (Increase from initial level:5,873 mm, 267 mm increase since 16:00 on March 7) O.P.+ 2,930 mm (Increase from initial level:3,656 mm, 3 mm increase since 16:00 on March 7) O.P.+ 4,434 mm (Water level from floor:638 mm, 16 mm increase since 16:00 on March 7)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 13:55 on March 7)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 13:48 on March 7)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:45 on March 1   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:07 on March 2   Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	・In order to conduct the work to improve the reliability of water treatment facilities, the cesium adsorption apparatus will be out of service until March 15. ・In order to conduct the work to improve the reliability of water treatment facilities, the 2nd Cesium Adsorption Apparatus will be out of service until March 10.				

For quick publication of the data of water level, values are provided as reference values.