

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 9)**

Water Level of the accumulated water (at 7:00 on March 9)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,253 mm (2 mm decrease since 16:00 on March 8)	O.P.+ 3,092 mm (13 mm increase since 16:00 on March 8)	—
	Water level of Turbine Building	O.P.+ 3,101 mm (15 mm increase since 16:00 on March 8)	O.P.+ 3,190 mm (1 mm decrease since 16:00 on March 8)	O.P.+ 3,073 mm (19 mm increase since 16:00 on March 8)	O.P.+ 3,052 mm (6 mm increase since 16:00 on March 8)
	Water level of Reactor Building	O.P.+ 4,606 mm (9 mm decrease since 16:00 on March 8)	O.P.+ 3,382 mm (No change since 16:00 on March 8)	O.P.+ 3,401 mm (24 mm increase since 16:00 on March 8)	O.P.+ 3,073 mm (7 mm increase since 16:00 on March 8)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,878 mm (Increase from initial level:6,095 mm, 124 mm increase since 16:00 on March 8) O.P.+ 2,944 mm (Increase from initial level:3,670 mm, 3 mm increase since 16:00 on March 8) O.P.+ 4,459 mm (Water level from floor:663 mm, 16 mm increase since 16:00 on March 8)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 13:55 on March 7)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:45 on March 1   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:07 on March 2   Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	・In order to conduct the work to improve the reliability of water treatment facilities, the cesium adsorption apparatus will be out of service until March 15. ・In order to conduct the work to improve the reliability of water treatment facilities, the 2nd Cesium Adsorption Apparatus will be out of service until March 10.				

For quick publication of the data of water level, values are provided as reference values.