

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on March 9)**

Water Level of the accumulated water (at 16:00 on March 9)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,253 mm (No change since 7:00 on March 9)	O.P.+ 3,101 mm (9 mm increase since 7:00 on March 9)	—
	Water level of Turbine Building	O.P.+ 3,111 mm (10 mm increase since 7:00 on March 9)	O.P.+ 3,191 mm (1 mm increase since 7:00 on March 9)	O.P.+ 3,094 mm (21 mm increase since 7:00 on March 9)	O.P.+ 3,062 mm (10 mm increase since 7:00 on March 9)
	Water level of Reactor Building	O.P.+ 4,591 mm (15 mm decrease since 7:00 on March 9)	O.P.+ 3,382 mm (No change since 7:00 on March 9)	O.P.+ 3,410 mm (9 mm increase since 7:00 on March 9)	O.P.+ 3,079 mm (6 mm increase since 7:00 on March 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,952 mm (Increase from initial level:6,169 mm, 74 mm increase since 7:00 on March 9) O.P.+ 2,950 mm (Increase from initial level:3,676 mm, 6 mm increase since 7:00 on March 9) O.P.+ 4,470 mm (Water level from floor:674 mm, 11 mm increase since 7:00 on March 9)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 13:55 on March 7)	—	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank		Transfer Completed (From 10:00 on March 9 to 16:00 on March 9)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:45 on March 1 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:07 on March 2 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	· In order to conduct the work to improve the reliability of water treatment facilities, the cesium adsorption apparatus will be out of service until March 15. · In order to conduct the work to improve the reliability of water treatment facilities, the 2nd Cesium Adsorption Apparatus will be out of service until March 10.				

For quick publication of the data of water level, values are provided as reference values.