

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 10)**

Water Level of the accumulated water (at 7:00 on March 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,256 mm (3 mm increase since 16:00 on March 9)	O.P.+ 3,115 mm (14 mm increase since 16:00 on March 9)	—
	Water level of Turbine Building	O.P.+ 3,131 mm (20 mm increase since 16:00 on March 9)	O.P.+ 3,191 mm (No change since 16:00 on March 9)	O.P.+ 3,109 mm (15 mm increase since 16:00 on March 9)	O.P.+ 3,074 mm (12 mm increase since 16:00 on March 9)
	Water level of Reactor Building	O.P.+ 4,595 mm (4 mm increase since 16:00 on March 9)	O.P.+ 3,383 mm (1 mm increase since 16:00 on March 9)	O.P.+ 3,427 mm (17 mm increase since 16:00 on March 9)	O.P.+ 3,093 mm (14 mm increase since 16:00 on March 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,089 mm (Increase from initial level:6,306 mm, 137 mm increase since 16:00 on March 9) O.P.+ 2,965 mm (Increase from initial level:3,691 mm, 15 mm increase since 16:00 on March 9) O.P.+ 4,490 mm (Water level from floor:694 mm, 20 mm increase since 16:00 on March 9)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 13:55 on March 7)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:45 on March 1 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:07 on March 2 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	・In order to conduct the work to improve the reliability of water treatment facilities, the cesium adsorption apparatus will be out of service until March 15. ・In order to conduct the work to improve the reliability of water treatment facilities, the 2nd Cesium Adsorption Apparatus will be out of service until March 10.				

For quick publication of the data of water level, values are provided as reference values.