

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on March 10)**

Water Level of the accumulated water (at 16:00 on March 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,258 mm (2 mm increase since 7:00 on March 10)	O.P.+ 3,118 mm (3 mm increase since 7:00 on March 10)	—
	Water level of Turbine Building	O.P.+ 3,145 mm (14 mm increase since 7:00 on March 10)	O.P.+ 3,194 mm (3 mm increase since 7:00 on March 10)	O.P.+ 3,106 mm (3 mm decrease since 7:00 on March 10)	O.P.+ 3,083 mm (9 mm increase since 7:00 on March 10)
	Water level of Reactor Building	O.P.+ 4,611 mm (16 mm increase since 7:00 on March 10)	O.P.+ 3,388 mm (5 mm increase since 7:00 on March 10)	O.P.+ 3,431 mm (4 mm increase since 7:00 on March 10)	O.P.+ 3,103 mm (10 mm increase since 7:00 on March 10)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,175 mm (Increase from initial level:6,392 mm, 86 mm increase since 7:00 on March 10) O.P.+ 3,090 mm (Increase from initial level:3,816 mm, 125 mm increase since 7:00 on March 10) O.P.+ 4,503 mm (Water level from floor:707 mm, 13 mm increase since 7:00 on March 10)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 13:55 on March 7)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:10 on March 10)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:45 on March 1   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:00 on March 10   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	· In order to conduct the work to improve the reliability of water treatment facilities, the cesium adsorption apparatus will be out of service until March 15. · Since works to improve the reliability of water treatment facilities has finished, the 2nd Cesium Adsorption Apparatus has started testing operation from 5:00 pm of March 10.				

For quick publication of the data of water level, values are provided as reference values.