

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 11)**

Water Level of the accumulated water (at 7:00 on March 11)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,265 mm (7 mm increase since 16:00 on March 10)	O.P.+ 3,119 mm (1 mm increase since 16:00 on March 10)	—
	Water level of Turbine Building	O.P.+ 3,166 mm (21 mm increase since 16:00 on March 10)	O.P.+ 3,199 mm (5 mm increase since 16:00 on March 10)	O.P.+ 3,095 mm (11 mm decrease since 16:00 on March 10)	O.P.+ 3,088 mm (5 mm increase since 16:00 on March 10)
	Water level of Reactor Building	O.P.+ 4,648 mm (37 mm increase since 16:00 on March 10)	O.P.+ 3,393 mm (5 mm increase since 16:00 on March 10)	O.P.+ 3,417 mm (14 mm decrease since 16:00 on March 10)	O.P.+ 3,107 mm (4 mm increase since 16:00 on March 10)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,314 mm (Increase from initial level:6,531 mm, 139 mm increase since 16:00 on March 10) O.P.+ 2,848 mm (Increase from initial level:3,574 mm, 242 mm decrease since 16:00 on March 10) O.P.+ 4,527 mm (Water level from floor:731 mm, 24 mm increase since 16:00 on March 10)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:47 on March 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:10 on March 10)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:45 on March 1   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 18:34 on March 10   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	· From 13:55 on March 7th we had transfer the accumulated water in the basement of the Turbine Building of Unit 2 to Centralized Radiation Waste Treatment Facility (Process Main Building) but stopped it at 8:30 on March 11. At 8:47 on March 11, we decided to transfer the water to Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building). ·In order to conduct the work to improve the reliability of water treatment facilities, the cesium adsorption apparatus will be out of service until March 15. ·As the work to improve the reliability of water treatment facilities has completed, at 17:00 on March 10, the 2nd Cesium Adsorption Apparatus (SARRY) started trial operation. As it was confirmed that the apparatus had no problems for its operation, at 18:34 on the day it resumed normal operation.				

For quick publication of the data of water level, values are provided as reference values.