

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 12)**

Water Level of the accumulated water※ (at 7:00 on March 12)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,281 mm (9 mm increase since 16:00 on March 11)	O.P.+ 3,116 mm (2 mm decrease since 16:00 on March 11)	—
	Water level of Turbine Building	O.P.+ 3,198 mm (20 mm increase since 16:00 on March 11)	O.P.+ 3,213 mm (8 mm increase since 16:00 on March 11)	O.P.+ 3,084 mm (7 mm decrease since 16:00 on March 11)	O.P.+ 3,081 mm (3 mm decrease since 16:00 on March 11)
	Water level of Reactor Building	O.P.+ 4,668 mm (22 mm increase since 16:00 on March 11)	O.P.+ 3,406 mm (9 mm increase since 16:00 on March 11)	O.P.+ 3,403 mm (8 mm decrease since 16:00 on March 11)	O.P.+ 3,104 mm (2 mm decrease since 16:00 on March 11)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,337 mm (Increase from initial level:6,554 mm, 6 mm increase since 16:00 on March 11) O.P.+ 2,898 mm (Increase from initial level:3,624 mm, 54 mm increase since 16:00 on March 11) O.P.+ 4,564 mm (Water level from floor:768 mm, 21 mm increase since 16:00 on March 11)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:47 on March 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:10 on March 10)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:45 on March 1   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 18:34 on March 10   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	•In order to conduct the work to improve the reliability of water treatment facilities, the cesium adsorption apparatus will be out of service until March 15. •At 8:37 on March 12th, we started to transfer the accumulated water from On-site Bunker Building to Process Main Building.				

※ For quick publication of the data of water level, values are provided as reference values.