

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on March 12)**

Water Level of the accumulated water (at 16:00 on March 12)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,286 mm (5 mm increase since 7:00 on March 12)	O.P.+ 3,112 mm (4 mm decrease since 7:00 on March 12)	—
	Water level of Turbine Building	O.P.+ 3,210 mm (12 mm increase since 7:00 on March 12)	O.P.+ 3,219 mm (6 mm increase since 7:00 on March 12)	O.P.+ 3,079 mm (5 mm decrease since 7:00 on March 12)	O.P.+ 3,079 mm (2 mm decrease since 7:00 on March 12)
	Water level of Reactor Building	O.P.+ 4,672 mm (4 mm increase since 7:00 on March 12)	O.P.+ 3,409 mm (3 mm increase since 7:00 on March 12)	O.P.+ 3,401 mm (2 mm decrease since 7:00 on March 12)	O.P.+ 3,099 mm (5 mm decrease since 7:00 on March 12)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,401 mm (Increase from initial level:6,618 mm, 64 mm increase since 7:00 on March 12) O.P.+ 2,937 mm (Increase from initial level:3,663 mm, 39 mm increase since 7:00 on March 12) O.P.+ 4,376 mm (Water level from floor:580 mm, 188 mm decrease since 7:00 on March 12)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:47 on March 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:10 on March 10)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on March 12 to 16:00 on March 12)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:45 on March 1 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 18:34 on March 10 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	·In order to conduct the work to improve the reliability of water treatment facilities, the cesium adsorption apparatus will be out of service until March 15. ·From 8:37 to 13:31, we transferred the water accumulated in the site banker building to the process main building.				

For quick publication of the data of water level, values are provided as reference values.