

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 13)**

Water Level of the accumulated water (at 7:00 on March 13)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,292 mm (6 mm increase since 16:00 on March 12)	O.P.+ 3,106 mm (6 mm decrease since 16:00 on March 12)	—
	Water level of Turbine Building	O.P.+ 3,226 mm (16 mm increase since 16:00 on March 12)	O.P.+ 3,223 mm (4 mm increase since 16:00 on March 12)	O.P.+ 3,073 mm (6 mm decrease since 16:00 on March 12)	O.P.+ 3,077 mm (2 mm decrease since 16:00 on March 12)
	Water level of Reactor Building	O.P.+ 4,659 mm (13 mm decrease since 16:00 on March 12)	O.P.+ 3,412 mm (3 mm increase since 16:00 on March 12)	O.P.+ 3,394 mm (7 mm decrease since 16:00 on March 12)	O.P.+ 3,095 mm (4 mm decrease since 16:00 on March 12)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,405 mm (Increase from initial level:6,622 mm, 4 mm increase since 16:00 on March 12) O.P.+ 3,035 mm (Increase from initial level:3,761 mm, 98 mm increase since 16:00 on March 12) O.P.+ 4,393 mm (Water level from floor:597 mm, 17 mm increase since 16:00 on March 12)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:47 on March 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:10 on March 10)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:45 on March 1   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 5:43 on March 13   Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	·In order to conduct the work to improve the reliability of water treatment facilities, the cesium adsorption apparatus will be out of service until March 15. ·The second cesium adsorption apparatus (SARRY) is stopped due to start of operation of the substation (66kV south-side switch station) followed by the suspension of off-site power supply and modification in the structure of the on-site power system (switching the power reception).				

For quick publication of the data of water level, values are provided as reference values.