

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 14)**

Water Level of the accumulated water (at 7:00 on March 14)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,297 mm (2 mm increase since 16:00 on March 13)	O.P.+ 3,123 mm (16 mm increase since 16:00 on March 13)	—
	Water level of Turbine Building	O.P.+ 3,250 mm (14 mm increase since 16:00 on March 13)	O.P.+ 3,227 mm (2 mm increase since 16:00 on March 13)	O.P.+ 3,110 mm (22 mm increase since 16:00 on March 13)	O.P.+ 3,074 mm (3 mm increase since 16:00 on March 13)
	Water level of Reactor Building	O.P.+ 4,615 mm (27 mm decrease since 16:00 on March 13)	O.P.+ 3,416 mm (2 mm increase since 16:00 on March 13)	O.P.+ 3,431 mm (25 mm increase since 16:00 on March 13)	O.P.+ 3,096 mm (3 mm increase since 16:00 on March 13)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,415 mm (Increase from initial level:6,632 mm, 7 mm increase since 16:00 on March 13) O.P.+ 2,886 mm (Increase from initial level:3,612 mm, 289 mm decrease since 16:00 on March 13) O.P.+ 4,418 mm (Water level from floor:622 mm, 15 mm increase since 16:00 on March 13)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:47 on March 11)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:45 on March 1 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:09 on March 14 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	・In order to conduct the work to improve the reliability of water treatment facilities, the cesium adsorption apparatus will be out of service until March 15. ・In order to check the soundness of the transfer line from the Centralized Radioactive Waste Treatment Facilities (Process Main Building) to the 2nd cesium adsorption apparatus (Sarry) newly established to improve the reliability of the water treatment, the apparatus will be out of service until 9:00 pm on March 14.				

For quick publication of the data of water level, values are provided as reference values.