

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 16)**

Water Level of the accumulated water (at 7:00 on March 16)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,304 mm (2 mm increase since 16:00 on March 15)	O.P.+ 3,134 mm (7 mm decrease since 16:00 on March 15)	—
	Water level of Turbine Building	O.P.+ 3,296 mm (14 mm increase since 16:00 on March 15)	O.P.+ 3,234 mm (1 mm increase since 16:00 on March 15)	O.P.+ 3,106 mm (16 mm decrease since 16:00 on March 15)	O.P.+ 3,099 mm (5 mm decrease since 16:00 on March 15)
	Water level of Reactor Building	O.P.+ 4,539 mm (27 mm decrease since 16:00 on March 15)	O.P.+ 3,422 mm (1 mm decrease since 16:00 on March 15)	O.P.+ 3,183 mm (16 mm decrease since 16:00 on March 15)	O.P.+ 3,119 mm (2 mm decrease since 16:00 on March 15)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,301 mm (Increase from initial level:6,518 mm, 101 mm decrease since 16:00 on March 15) O.P.+ 3,067 mm (Increase from initial level:3,793 mm, 47 mm increase since 16:00 on March 15) O.P.+ 4,477 mm (Water level from floor:681 mm, 21 mm increase since 16:00 on March 15)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:47 on March 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:46 on March 15)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:40 on March 15 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 19:39 on March 14 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.