Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 18:00 on March 16)

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on March 16)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,305 mm (1 mm increase since 7:00 on March 16)	O.P.+ 3,130 mm (4 mm decrease since 7:00 on March 16)	_
	Water level of Turbine Building	O.P.+ 3,305 mm (9 mm increase since 7:00 on March 16)	O.P.+ 3,234 mm (No change since 7:00 on March 16)	O.P.+ 3,100 mm (6 mm decrease since 7:00 on March 16)	O.P.+ 3,096 mm (3 mm decrease since 7:00 on March 16)
	Water level of Reactor Building	O.P.+ 4,507 mm (32 mm decrease since 7:00 on March 16)	O.P.+ 3,423 mm (1 mm increase since 7:00 on March 16)	O.P.+ 3,176 mm (7 mm decrease since 7:00 on March 16)	O.P.+ 3,117 mm (2 mm decrease since 7:00 on March 16)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,281 mm (Increase from initial level:6,498 mm, 20 mm decrease since 7:00 on March 16) O.P.+ 3,302 mm (Increase from initial level:4,028 mm, 235 mm increase since 7:00 on March 16) O.P.+ 4,491 mm (Water level from floor:695 mm, 14 mm increase since 7:00 on March 16)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		_	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:47 on March 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:46 on March 15)	_
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on March 16 to 16:00 on March 16)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:58 on March 16 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 14:36 on March 16 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	Due to the commencement of the operation of south switching station, it was necessary to switch the power receiving of the power plant. Thus at 10:01 am of March 16 we suspended the first Cesium adsorption apparatus and at 10:02 am on the same day we suspended the second Cesium adsorption apparatus. After the switching works were completed, at 2:32 pm on the same day, we activated the second Cesium adsorption apparatus and at 10:02 am on the same day we suspended the second Cesium adsorption apparatus. After the switching works were				
	he first Cesium adsorption apparatus. and at 2:58 pm it reached the rated flow (19.8m ³ /h).				

For quick publication of the data of water level, values are provided as reference values.