

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 17)**

Water Level of the accumulated water (at 7:00 on March 17)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,306 mm (1 mm increase since 16:00 on March 16)	O.P.+ 3,125 mm (5 mm decrease since 16:00 on March 16)	—
	Water level of Turbine Building	O.P.+ 3,316 mm (11 mm increase since 16:00 on March 16)	O.P.+ 3,236 mm (2 mm increase since 16:00 on March 16)	O.P.+ 3,090 mm (10 mm decrease since 16:00 on March 16)	O.P.+ 3,090 mm (6 mm decrease since 16:00 on March 16)
	Water level of Reactor Building	O.P.+ 4,492 mm (15 mm decrease since 16:00 on March 16)	O.P.+ 3,426 mm (3 mm increase since 16:00 on March 16)	O.P.+ 3,174 mm (2 mm decrease since 16:00 on March 16)	O.P.+ 3,110 mm (7 mm decrease since 16:00 on March 16)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,176 mm (Increase from initial level:6,393 mm, 105 mm decrease since 16:00 on March 16) O.P.+ 3,340 mm (Increase from initial level:4,066 mm, 38 mm increase since 16:00 on March 16) O.P.+ 4,519 mm (Water level from floor:723 mm, 28 mm increase since 16:00 on March 16)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:47 on March 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:46 on March 15)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:58 on March 16 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 14:36 on March 16 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.