

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 18)**

Water Level of the accumulated water (at 7:00 on March 18)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,308 mm (2 mm increase since 16:00 on March 17)	O.P.+ 3,115 mm (5 mm decrease since 16:00 on March 17)	—
	Water level of Turbine Building	O.P.+ 3,339 mm (14 mm increase since 16:00 on March 17)	O.P.+ 3,239 mm (3 mm increase since 16:00 on March 17)	O.P.+ 3,078 mm (8 mm decrease since 16:00 on March 17)	O.P.+ 3,081 mm (4 mm decrease since 16:00 on March 17)
	Water level of Reactor Building	O.P.+ 4,532 mm (41 mm increase since 16:00 on March 17)	O.P.+ 3,431 mm (1 mm increase since 16:00 on March 17)	O.P.+ 3,154 mm (7 mm decrease since 16:00 on March 17)	O.P.+ 3,100 mm (7 mm decrease since 16:00 on March 17)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,015 mm (Increase from initial level:6,232 mm, 102 mm decrease since 16:00 on March 17) O.P.+ 3,408 mm (Increase from initial level:4,134 mm, 43 mm increase since 16:00 on March 17) O.P.+ 4,558 mm (Water level from floor:762 mm, 25 mm increase since 16:00 on March 17)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:47 on March 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:46 on March 15)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:58 on March 16 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 14:36 on March 16 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.