

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on March 18)**

Water Level of the accumulated water (at 16:00 on March 18)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,309 mm (1 mm increase since 7:00 on March 18)	O.P.+ 3,115 mm (No change since 7:00 on March 18)	—
	Water level of Turbine Building	O.P.+ 3,346 mm (7 mm increase since 7:00 on March 18)	O.P.+ 3,239 mm (No change since 7:00 on March 18)	O.P.+ 3,095 mm (17 mm increase since 7:00 on March 18)	O.P.+ 3,078 mm (3 mm decrease since 7:00 on March 18)
	Water level of Reactor Building	O.P.+ 4,511 mm (21 mm decrease since 7:00 on March 18)	O.P.+ 3,435 mm (4 mm increase since 7:00 on March 18)	O.P.+ 3,167 mm (13 mm increase since 7:00 on March 18)	O.P.+ 3,098 mm (2 mm decrease since 7:00 on March 18)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,006 mm (Increase from initial level:6,223 mm, 9 mm decrease since 7:00 on March 18) O.P.+ 3,145 mm (Increase from initial level:3,871 mm, 263 mm decrease since 7:00 on March 18) O.P.+ 4,572 mm (Water level from floor:776 mm, 14 mm increase since 7:00 on March 18)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:13 on March 18)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 8:46 on March 15 to 10:00 on March 18)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:58 on March 16 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 14:36 on March 16 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* 1 :The accumulated water transferred from Basement of Unit 2 Turbine Building to Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) from 8:47 on March 11 to 9:37 March 18.				

For quick publication of the data of water level, values are provided as reference values.