

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 21)**

Water Level of the accumulated water (at 7:00 on March 21)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,284 mm (10 mm decrease since 16:00 on March 20)	O.P.+ 3,110 mm (5 mm decrease since 16:00 on March 20)	—
	Water level of Turbine Building	O.P.+ 3,066 mm (227 mm decrease since 16:00 on March 20)	O.P.+ 3,213 mm (10 mm decrease since 16:00 on March 20)	O.P.+ 3,072 mm (10 mm decrease since 16:00 on March 20)	O.P.+ 3,077 mm (2 mm decrease since 16:00 on March 20)
	Water level of Reactor Building	O.P.+ 4,508 mm (24 mm increase since 16:00 on March 20)	O.P.+ 3,406 mm (10 mm decrease since 16:00 on March 20)	O.P.+ 3,151 mm (10 mm decrease since 16:00 on March 20)	O.P.+ 3,096 mm (6 mm decrease since 16:00 on March 20)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,051 mm (Increase from initial level:6,268 mm, 104 mm decrease since 16:00 on March 20) O.P.+ 2,502 mm (Increase from initial level:3,228 mm, 239 mm increase since 16:00 on March 20) O.P.+ 4,341 mm (Water level from floor:545 mm, 18 mm increase since 16:00 on March 20)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building →Basement of Unit 2 Turbine Building Currently being transferred (Since 9:37 on March 20)	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on March 20)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:41 on March 19)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:58 on March 16 In operation 2nd Cesium Adsorption Apparatus (Sarry): From 14:36 on March 16 to 8:30 on March 21 Operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	2nd Cesium adsorption apparatus (SARRY) was suspended at 8:30 am on March 21, 2012 and cleaning of its filter is in process.				

For quick publication of the data of water level, values are provided as reference values.