

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on March 21)**

Water Level of the accumulated water (at 16:00 on March 21)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,264 mm (20 mm decrease since 7:00 on March 21)	O.P.+ 3,106 mm (4 mm decrease since 7:00 on March 21)	—
	Water level of Turbine Building	O.P.+ 3,028 mm (38 mm decrease since 7:00 on March 21)	O.P.+ 3,195 mm (18 mm decrease since 7:00 on March 21)	O.P.+ 3,067 mm (5 mm decrease since 7:00 on March 21)	O.P.+ 3,071 mm (6 mm decrease since 7:00 on March 21)
	Water level of Reactor Building	O.P.+ 4,504 mm (4 mm decrease since 7:00 on March 21)	O.P.+ 3,395 mm (11 mm decrease since 7:00 on March 21)	O.P.+ 3,147 mm (4 mm decrease since 7:00 on March 21)	O.P.+ 3,092 mm (4 mm decrease since 7:00 on March 21)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,995 mm (Increase from initial level:6,212 mm, 56 mm decrease since 7:00 on March 21) O.P.+ 2,770 mm (Increase from initial level:3,496 mm, 268 mm increase since 7:00 on March 21) O.P.+ 4,345 mm (Water level from floor:549 mm, 4 mm increase since 7:00 on March 21)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building →Basement of Unit 2 Turbine Building Transfer Completed (From 9:37 on March 20 to 9:48 on March 21)	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on March 20)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:41 on March 19)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:58 on March 16 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:05 on March 21 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	2nd Cesium adsorption apparatus (SARRY) was suspended at 8:30 am on March 21, 2012 and its filter was cleansed. After the cleansing, the apparatus restarted at 11:48 am. The flow rate has been steady since 12:05 pm.				

For quick publication of the data of water level, values are provided as reference values.