

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 22)**

Water Level of the accumulated water (at 7:00 on March 22)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,219 mm (45 mm decrease since 16:00 on March 21)	O.P.+ 3,099 mm (7 mm decrease since 16:00 on March 21)	—
	Water level of Turbine Building	O.P.+ 3,042 mm (14 mm increase since 16:00 on March 21)	O.P.+ 3,158 mm (37 mm decrease since 16:00 on March 21)	O.P.+ 3,059 mm (8 mm decrease since 16:00 on March 21)	O.P.+ 3,066 mm (5 mm decrease since 16:00 on March 21)
	Water level of Reactor Building	O.P.+ 4,482 mm (22 mm decrease since 16:00 on March 21)	O.P.+ 3,357 mm (38 mm decrease since 16:00 on March 21)	O.P.+ 3,138 mm (9 mm decrease since 16:00 on March 21)	O.P.+ 3,085 mm (7 mm decrease since 16:00 on March 21)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,906 mm (Increase from initial level:6,123 mm, 89 mm decrease since 16:00 on March 21) O.P.+ 3,049 mm (Increase from initial level:3,775 mm, 279 mm increase since 16:00 on March 21) O.P.+ 4,361 mm (Water level from floor:565 mm, 16 mm increase since 16:00 on March 21)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on March 20)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:41 on March 19)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:58 on March 16 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:05 on March 21 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.