

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 23)**

Water Level of the accumulated water (at 7:00 on March 23)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,201 mm (3 mm decrease since 16:00 on March 22)	O.P.+ 3,090 mm (7 mm decrease since 16:00 on March 22)	—
	Water level of Turbine Building	O.P.+ 3,064 mm (13 mm increase since 16:00 on March 22)	O.P.+ 3,140 mm (2 mm decrease since 16:00 on March 22)	O.P.+ 3,046 mm (9 mm decrease since 16:00 on March 22)	O.P.+ 3,051 mm (12 mm decrease since 16:00 on March 22)
	Water level of Reactor Building	O.P.+ 4,469 mm (2 mm increase since 16:00 on March 22)	O.P.+ 3,330 mm (7 mm decrease since 16:00 on March 22)	O.P.+ 3,124 mm (9 mm decrease since 16:00 on March 22)	O.P.+ 3,074 mm (7 mm decrease since 16:00 on March 22)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,768 mm (Increase from initial level:5,985 mm, 87 mm decrease since 16:00 on March 22) O.P.+ 3,251 mm (Increase from initial level:3,977 mm, 60 mm increase since 16:00 on March 22) O.P.+ 4,386 mm (Water level from floor:590 mm, 14 mm increase since 16:00 on March 22)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on March 20)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:41 on March 19)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:58 on March 16 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:05 on March 21 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.