

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 24)**

Water Level of the accumulated water (at 7:00 on March 24)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,205 mm (6 mm increase since 16:00 on March 23)	O.P.+ 3,090 mm (5 mm increase since 16:00 on March 23)	—
	Water level of Turbine Building	O.P.+ 3,090 mm (19 mm increase since 16:00 on March 23)	O.P.+ 3,143 mm (6 mm increase since 16:00 on March 23)	O.P.+ 3,047 mm (7 mm increase since 16:00 on March 23)	O.P.+ 3,043 mm (1 mm decrease since 16:00 on March 23)
	Water level of Reactor Building	O.P.+ 4,540 mm (101 mm increase since 16:00 on March 23)	O.P.+ 3,343 mm (15 mm increase since 16:00 on March 23)	O.P.+ 3,127 mm (8 mm increase since 16:00 on March 23)	O.P.+ 3,069 mm (No change since 16:00 on March 23)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,627 mm (Increase from initial level:5,844 mm, 87 mm decrease since 16:00 on March 23) O.P.+ 3,373 mm (Increase from initial level:4,099 mm, 71 mm increase since 16:00 on March 23) O.P.+ 4,413 mm (Water level from floor:617 mm, 17 mm increase since 16:00 on March 23)		
Situation of transfer of the accumulated water		Unit 1	Unit 2 * 1	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on March 20)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:41 on March 19)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:58 on March 16 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:05 on March 21 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.